

# Declaration of Conformity


in accordance with European Standard EN 14624:2005

It is hereby certified that **AccuTools** model number **eL-520 Refrigerant Leak Detector** has been tested and is declared in conformance to European Standard EN 14624:2005 Performance Of Mobile Leak Detectors Of Halogenated Refrigerants.

Testing has been conducted using test equipment as defined by relevant standards, using an NIST traceable leak source. The unit met the sensitivity, accuracy and performance requirements defined by the standard as described below:

Stationary Test Threshold  $\leq 3$  g/yr

Moving Test Threshold  $\leq 3$  g/yr

Signed:  J. M. Powers / w151

Dated: April 14, 2009